

	Date	Time	Latitude	Longitude	Material at Origin	Land Use at Origin	Size	Suppressed by	Suppressing Agency	Facility Identification/Circuit	Other Companies	Voltage (Volts)	Equipment Involved With Ignition	Type	Was There an Outage	Date	Time	Suspected Initiating Event	Equipment /Facility Failure	Contact From Object	Facility Contacted	Contributing Factor
SDG&E	2/7/15	13:36	32.9021000	-117.0137	Vegetation	Rural	Less Than 25 Acres	Utility		TL23041	none	230kV	Conductor	Overhead	Yes	2/7/15	13:36	Contact From Object		Animal	Electric Facility	Unknown
SDG&E	2/11/15	15:30	32.8941000	-116.9393	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Lakeside Fire	Service span off 237657		12kV	Conductor	Overhead	No			Contact From Object		Vegetation	Electric Facility	Weather
SDG&E	3/19/15	23:50	33.0323780	-117.0159	Vegetation	Rural	Less Than 25 Acres	Fire Agency	S.D. City	P719156		12kV	Conductor	Overhead	Yes	3/19/15	23:50	Contact From Object		Vehicle	Pole	Human Error
SDG&E	4/9/15	17:23	32.7233000	-116.8922	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	P171928		12kV	Lightning	Overhead	No			Unknown				Unknown
SDG&E	4/12/15	14:30	33.2754150	-117.330589	Vegetation	Rural	100 - 299 Acres	Fire Agency	Pendleton	P164638		12kV	Overhead	Overhead	No			Contact From Object		Vehicle	Pole	None
SDG&E	4/12/15	12:31	33.0117000	-116.8660	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	P214319		12kV	Conductor	Overhead	Yes	4/12/15	12:30	Contact From Object		Other	Electric Facility	None
SDG&E	4/13/15	10:50	32.5859000	-117.0017	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Chula Vista	P81123		12kV	Conductor	Overhead	Yes	4/13/15	10:50	Contact From Object		Vehicle	Electric Facility	Human Error
SDG&E	4/18/15	12:00	32.7764000	-116.9309	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P677849		230kV	Conductor	Overhead	No			Contact From Object		Vegetation	Electric Facility	None
SDG&E	4/28/15	13:30	32.8917000	-116.8419	Vegetation	Rural	Less Than 25 Acres	Customer		P176657	none	12kV	Other	Overhead	Yes	4/28/15	13:30	Contact From Object		Vehicle	Electric Facility	Human Error
SDG&E	4/29/15	12:00	32.6061000	-116.8960	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P175961	none	12kV	Conductor	Overhead	Yes	4/29/15	12:00	Contact From Object		Vegetation	Electric Facility	Unknown
SDG&E	5/17/15	6:55	33.1808000	-117.2064	Vegetation	Rural	Less Than 25 Acres	Self Extinguished		P15839		12kV	Conductor	Overhead	Yes	5/17/15	7:06	Contact From Object		Other	Electric Facility	None
SDG&E	5/28/15	12:45	32.7265000	-116.9922	Vegetation	Rural	Less Than 25 Acres	Self Extinguished		P196508		12kV	Conductor	Overhead	Yes	5/28/15	12:45	Contact From Object		Balloons	Electric Facility	None
SDG&E	6/9/15	5:50	32.9003000	-117.2309	Vegetation	Urban	Less Than 25 Acres	Fire Agency	S.D. City	Z63404		69kV	Conductor	Overhead	Yes	6/9/15	5:45	Contact From Object		Animal	Electric Facility	Outside Force
SDG&E	7/7/15	15:00	32.7443000	-117.0498	Vegetation	Urban	Less Than 25 Acres	Utility		Z371043 Cir. 160		12kV	Conductor	Overhead	Yes	7/7/15	13:00	Contact From Object		Other	Electric Facility	Human Error
SDG&E	7/13/15	23:45	32.7629700	-116.8995	Vegetation	Rural	Less Than 25 Acres	Self Extinguished		Z971870 Cir 23041		230kV	Conductor	Overhead	No			Contact From Object		Balloons	Electric Facility	Outside Force
SDG&E	7/17/15	9:48	33.1750420	-117.0125	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P213348		12kV	Conductor	Overhead	No			Contact From Object		Vegetation	Communication Facility	Human Error
SDG&E	7/27/15	14:30	33.0665000	-116.5790	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P212006		12kV	Conductor	Overhead	Yes	7/27/15	14:30	Contact From Object		Vegetation	Electric Facility	None
SDG&E	8/8/15	10:00	33.1973000	-117.2308	Vegetation	Urban	Less Than 25 Acres	Customer		P17530J		4kV	Conductor	Overhead	Yes	8/8/15	10:00	Contact From Object		Balloons	Electric Facility	None
SDG&E	8/13/15	20:33	33.2457100	-116.6769	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P19586		12kV	Conductor	Overhead	Yes	8/13/15	20:33	Unknown		Vegetation	Electric Facility	None
SDG&E	8/15/15	17:30	32.7417200	-116.9685	Other	Urban	Less Than 25 Acres	Customer		P273868		4kV	Other	Overhead	No			Equipment/Facility Failure	Splice/Clamp/Connector	Vehicle	Electric Facility	None
SDG&E	8/23/15	15:00	33.2729100	-117.1521	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	P415300		12kV	Conductor	Overhead	Yes	8/23/15	15:00	Contact From Object		Vegetation	Electric Facility	Weather
SDG&E	9/1/15	18:01	32.7595000	-117.0671	Vegetation	Urban	Less Than 25 Acres	Self Extinguished		P270259 cir. RD4		4kV	Conductor	Overhead	No			Contact From Object		Vehicle	Electric Facility	Human Error
SDG&E	9/1/15	8:50	32.6690000	-116.2860	Vegetation	Rural	Less Than 25 Acres	Utility		P41145 cir. 445		12kV	Conductor	Overhead	Yes	9/1/15	8:50	Equipment/Facility Failure	Conductor			None
SDG&E	9/2/15	18:16	33.1867000	-117.2020	Vegetation	Urban	Less Than 25 Acres	Self Extinguished		P111781 cir. 859		12kV	Conductor	Overhead	Yes	9/1/15	18:11	Contact From Object		Vehicle	Electric Facility	Human Error
SDG&E	9/8/15	11:45	33.0726000	-116.7436	Vegetation	Rural	Less Than 25 Acres	Utility		P416995 cir 222	none	12kV	Switch	Overhead	Yes	9/8/15	11:45	Equipment/Facility Failure	Switch			None
SDG&E	9/9/15	20:40	32.6439600	-117.0720	Vegetation	Urban	Less Than 25 Acres	Utility		P89691 - cir 255	none	12kV	Conductor	Overhead	Yes	9/9/15	20:40	Equipment/Facility Failure	Conductor			Unknown
SDG&E	9/17/15	8:09	32.6791420	-117.1044	Vegetation	Urban	Less Than 25 Acres	Fire Agency	National City	P835456	none	12kV	Conductor	Overhead	Yes	9/17/15	19:55	Equipment/Facility Failure	Transformer			None
SDG&E	10/2/15	14:30	33.1354000	-117.0588	Vegetation	Urban	Less Than 25 Acres	Customer		P510149		12kV	Conductor	Overhead	Yes	10/2/15	14:30	Equipment/Facility Failure	Splice/Clamp/Connector			Unknown
SDG&E	10/8/15	13:47	32.5918000	-116.9449	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	Z31746		69kV	Conductor	Overhead	No			Equipment/Facility Failure	Splice/Clamp/Connector			Unknown
SDG&E	10/9/15	16:00	32.7710500	-117.1085	Other	Urban	Less Than 25 Acres	Fire Agency	SDFD	P931983	telco	4kV	Conductor	Overhead	Yes	10/9/15	16:20	Equipment/Facility Failure	Conductor			Unknown
SDG&E	10/31/15 13:04:00 PM		33.3391670	-117.4948	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Pendleton	Z223694		230kV	Conductor	Overhead	No			Contact From Object				
SDG&E	12/26/15	3:04	33.1323000	-117.0695	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Escondido	P218563		12kV	Conductor	Overhead	Yes	12/26/15	3:04	Contact From Object		Animal	Electric Facility	Outside Force
SDG&E	1/3/16	4:30	33.1915000	-117.3655000	Other	Urban	Less Than 25 Acres	Fire Agency	O'Side FD	Sta. 580-564		12kV	Transformer	Padmounted	Yes	1/3/16	4:30	Contact From Object		Vehicle	Electric Facility	Other
SDG&E	1/9/16	4:30	33.0820000	-117.0910000	Vegetation	Urban	Less Than 25 Acres	Fire Agency	Escondido FD	P319659		12kV	Conductor	Overhead	Yes	1/9/16	4:30	Contact From Object		Vegetation	Electric Facility	Weather
SDG&E	1/16/16	14:42	32.7187640	-116.9745500	Vegetation	Urban	Less Than 25 Acres	Fire Agency	SMG/CAL FIRE	P270861		12kV	Conductor	Overhead	Yes	1/16/16	14:42	Contact From Object		Balloons	Electric Facility	None
SDG&E	1/31/16	15:00	33.3217000	-117.1660000	Vegetation	Urban	Less Than 25 Acres	Fire Agency	CAL FIRE	P714625		12kV	Conductor	Overhead	Yes	1/31/16	15:00	Equipment/Facility Failure	Conductor			Weather
SDG&E	2/5/16	9:47	33.0739000	-117.0862000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Escondido FD	P418131		12kV	Other	Overhead	Yes	2/5/16	9:47	Equipment/Facility Failure	Splice/Clamp/Connector			Unknown
SDG&E	2/12/16	19:30	33.2427420	-116.964380	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P414015		12kV	Conductor	Overhead	Yes	2/12/16	19:30	Vandalism/Theft				Outside Force
SDG&E	2/18/16	0:00	32.7083000	-116.3070000	Vegetation	Rural	Less Than 25 Acres	Utility		P408126		12kV	Conductor	Overhead	Yes	2/18/16	6:00	Contact From Object		Vehicle	Pole	None
SDG&E	3/3/16	6:00	32.8472430	-116.9420310	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Lakeside F.D	P874698	AT&T and Cox	12kV	Conductor	Overhead	Yes	3/3/16	6:30	Contact From Object		Vehicle	Pole	Human Error
SDG&E	3/11/16	11:40	33.1563180	-117.2151540	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Vista FD	P615947		12kV	Conductor	Overhead	Yes	3/11/16	11:40	Equipment/Facility Failure	Conductor			Unknown
SDG&E	4/6/16	10:38	33.1865500	-117.1967470	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Vista FD	P113372		12kV	Conductor	Overhead	Yes	4/6/16	10:38	Contact From Object		Vegetation	Electric Facility	Human Error
SDG&E	4/16/16 Unknown		33.2243310	-117.3682710	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Unknown	Z29145 (TL 690, C198)		12kV	Conductor	Overhead	Yes	4/16/16	16:00	Contact From Object		Vegetation	Electric Facility	Weather
SDG&E	6/12/16 Unknown		33.0940000	-117.0430000	Vegetation	Urban	Less Than 25 Acres	Utility	Utility	P712531		12kV	Conductor	Overhead	No			Contact From Object		Balloons	Electric Facility	None
SDG&E	6/14/16	6:05	32.8801460	-116.9050980	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P370041	AT&T	12kV	Conductor	Overhead	Yes	6/14/16	6:05	Contact From Object		Vehicle	Pole	Outside Force
SDG&E	6/23/16	15:00	32.8058000	-116.9610000	Vegetation	Urban	Less Than 25 Acres	Fire Agency	El Cajon FD	P166454		12kV	Conductor	Overhead	Yes	6/23/16	15:00	Contact From Object		Animal	Electric Facility	Outside Force
SDG&E	6/27/16	15:30	33.2837350	-116.6174110	Vegetation	Rural	Less Than 25 Acres	Customer		P112086		12kV	Other	Overhead	No			Equipment/Facility Failure	Splice/Clamp/Connector			Human Error
SDG&E	7/2/16	7:51	32.8100000	-116.8780000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P775960		12kV	Capacitor Bank	Overhead	Yes	7/2/16	7:51	Equipment/Facility Failure	Capacitor Bank			None
SDG&E	7/11/16	13:19	33.1148050	-116.5842710	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	CAL FIRE	P412649 C221	None	12kV	Lightning Arrestor	Overhead	Yes	7/11/16	13:19	Equipment/Facility Failure	Lightning Arrestor			None
SDG&E	7/11/16	10:27	33.2719600	-117.1625667	Vegetation	Urban	Less Than 25 Acres	Customer		P228931 C 520		12kV	Conductor	Overhead	Yes	7/11/16	10:27	Contact From Object		Other	Electric Facility	Human Error
SDG&E	7/22/16 Unknown		33.2014560	-116.9351990	Vegetation	Rural	Less Than 25 Acres	Utility		P212466		25kV	Transformer	Overhead	No			Equipment/Facility Failure	Other			Unknown
SDG&E	7/29/16	10:57	33.0709580	-116.7424310	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P416995		12kV	Conductor	Overhead	Yes	7/29/16		Equipment/Facility Failure	Conductor			Outside Force
SDG&E	7/31/16	13:43	33.3663000	-117.2033000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Fallbrook Fire	P115869		12kV	Conductor	Overhead	Yes	7/31/16	13:43	Contact From Object		Vegetation	Electric Facility	Unknown
SDG&E	8/27/16	12:43	33.1371290	-117.0761470	Vegetation	Rural	Less Than 25 Acres	Customer		P315560		12kV	Conductor	Overhead	Yes	8/27/16	12:43	Contact From Object		Balloons	Electric Facility	Unknown
SDG&E	9/23/16	11:25	32.7380370	-116.7332720	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P101347		12kV	Transformer	Overhead	Yes	9/23/16	11:25	Equipment/Facility Failure	Transformer			None
SDG&E	9/27/16 unknown		33.2966580	-117.2079410	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE			12kV	Fuse	Overhead	No			Contact From Object		Animal	Electric Facility	Unknown
SDG&E	9/29/16		32.7417750	-116.9653340	Vegetation	Urban	Less Than 25 Acres	Fire Agency	SMG/CAL FIRE	P26106		12kV	Conductor	Overhead	No			Contact Between Third Party Facility on Pole and Supply Lines			Communication Facility	Outside Force
SDG&E	9/29/16	8:14	33.1714430	-117.3157830	Vegetation	Urban	Less Than 25 Acres	Utility		Z524971	none	230kV	Conductor	Overhead	No			Unknown				Unknown
SDG&E	10/8/16	10:53	33.3018560	-117.0974220	Vegetation	Rural	26 - 9.99 Acres	Fire Agency	Valley Center	Z811329		230kV	Conductor	Overhead	Yes			Contact From Object		Other	Electric Facility	Other
SDG&E	10/21/16	11:20	33.0485000	-116.8615000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	CAL FIRE	P114079		12kV	Conductor	Overhead	No			Equipment/Facility Failure	Transformer			Other
SDG&E	11/2/16	10:30	32.8372640	-116.7021580	Vegetation	Rural	Less Than 25 Acres	Utility		P175475		12kV	Conductor	Overhead	Yes	11/2/16	10:30	Equipment/Facility Failure	Splice/Clamp/Connector			None
SDG&E	11/12/16	20:30	32.6258333	-116.9375000	Vegetation	Rural	Less Than 25 Acres	Fire Agency	Chula Vista Fire	P859												